



Fire Plug Inspection and Fault Report



Town _____

					Council use only	
Fault No	Street Name	House No	Fault Code	Insp Date	Authority	CRMs No
1	Smith Street	11	P	8/5/2022	EGS	24680

Fault No	Street Name	House No	Fault Code	Insp Date	Authority	CRMs No
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						

Fault Code		Authority	Notes
S - CD	Site clean-up required -Card left	CFA	
S - EGS	Site clean-up required	EGS	
P	Marker post/box needs repair	EGS	
C	Hydrant cap/blank cap missing	WB	
B	No box cover/hydrant cover	WB	
M	Missing or damaged marker post	EGS	
W	Marker post wrong direction	WB	
OK	Okay		
G	Hydrant plug cannot be located	WB	
R	Box or base requires resetting	WB	
D	Plug too deep for standpipe	WB	
L	Hydrant/Plug missing	WB	
I	Indicator	EGS	
O	Other	?	Provide more information on back page

CFA Country Fire Authority	EGSC East Gippsland Shire Council	WB East Gippsland Water
----------------------------	-----------------------------------	-------------------------

Signature: _____

Name: _____ Date ____/____/____

Return form to Emergency Management Co Ordinator East Gippsland Shire

Privacy Statement

The East Gippsland Shire Council asks for details about you to collect rates, approve permits and licences, and run a range of community services. The information you give to us on this form is used only for the reasons set out in the form and is not given to anybody else. Sometimes we may supply details about you to someone else, but only if we are allowed by law, or to protect someone or property. When information is given out, Council will always try to make sure your privacy is protected in line with the *Privacy and Data Protection Act 2014*. You may ask for more information about Council's Privacy Policy by contacting our Information Privacy Officer on 03 5153 9500 or e-mail feedback@egipps.vic.gov.au

JUL 2025



Fire Plug Inspection and Fault Report



Additional Faults Information

Example

Fault No	Address	Information
6	34 Smith	Access issue due to fence erected over hydrant

Fault No	Address	Information

Notes
