



Fire Plug Inspection and Fault Report



Town _____

					Council use only	
Fault No	Street Name	House No	Fault Code	Insp Date	Authority	CRMs No
1	Smith Street	11	P	8/5/2022	EGS	24680

Fault No	Street Name	House No	Fault Code	Insp Date	Authority	CRMs No
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						

Fault Code		Authority	Notes
S - CD	Site clean-up required -Card left	CFA	
S - EGS	Site clean-up required	EGS	
P	Marker post/box needs repair	EGS	
C	Hydrant cap/blank cap missing	WB	
B	No box cover/hydrant cover	WB	
M	Missing or damaged marker post	EGS	
W	Marker post wrong direction	WB	
OK	Okay		
G	Hydrant plug cannot be located	WB	
R	Box or base requires resetting	WB	
D	Plug too deep for standpipe	WB	
L	Hydrant/Plug missing	WB	
I	Indicator	EGS	
O	Other	?	Provide more information on back page

CFA Country Fire Authority	EGSC East Gippsland Shire Council	WB East Gippsland Water
----------------------------	-----------------------------------	-------------------------

Signature: _____

Name: _____ Date ____/____/____

Return form to Emergency Management Co Ordinator East Gippsland Shire

Collection notice:

East Gippsland Shire Council collects information provided by you in this form to inspect and report fire plugs. East Gippsland Shire Council will only disclose your personal contact information to a third-party where required to do so by law. Information shared in this situation will be in accordance with the requirements of the Privacy and Data Protection Act 2014. If incorrect information or details are provided Council will be unable to assist you with this request. For more information on Council's Privacy Policy, please visit Council's [Privacy Statement](#) on our website or email feedback@egipps.vic.gov.au if you have any questions. SEP 26

Additional Faults Information

Example

Fault No	Address	Information
6	34 Smith	Access issue due to fence erected over hydrant

Fault No	Address	Information

Notes
